

APPENDIX L: TANK INSPECITON FORM

SPCC MONTHLY PHYSICAL INSPECTIONS

TANK TYPE:

Date:	GASOLINE	DIESEL	WASTE OIL
Inspect valves & piping			
Inspect metal surface of tank & support			
Check for leaks at base of tank			
Check containment for leaks, cracks, etc...			
Containment cleaned & pumped (as needed basis)			
Tank secured / locked			
Are tanks labeled correctly?			
Is spill equipment present/accessible?			
Check that tank vents are clear of obstruction & operational			
Spill cleaned up			
SOP accessible for drainage of containment?			
SOP accessible for proper filling & withdrawal procedures?			

Comments:

Inspected by:

SPCC Annual Requirements

Test fuel gauge (once per year)

Employee briefing (once per year)